




འབྲུག་གློག་ཁེ་ལས་འཛིན།

**Bhutan Power Corporation Limited**  
(An ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018 Certified Company)  
**Registered Office, Thimphu**  
**Procurement Services Department**  
**Thimphu: Bhutan**



BPC/PSD/T&P/2022/05/178

April 1, 2022

**Subject:** **Addendum No. 2**

**Reference:** BPC/PSD/T&P/2022/05 for the Supply and Delivery of Tools and Plants dated March 12, 2022

Dear Sir(s),

This is in reference to the above-mentioned tender whereby PSD, BPC would like to issue the following responses to the clarifications sought by prospective bidders:

Lot	Item	Query	Response
Lot 5: Hand Tools	Item 5(2): Electrician's Tool Kit	What are pieces set and what tools are required?	As specified in the Technical Specification and the sample picture provided.
Lot 5: Hand Tools	Item 5(23): Insulated Torque Wrench M10, M12, M13 (for IPC)	Please let us know the square drive and NM	Maximum torque shall not exceed 20NM for conductor < 95 sq.mm. The size of the LV ABC cable is up to 95 sq.mm.
Lot 5: Hand Tools	Item 5(26): Bolt Cutter	What is the cutting capacity?	The equipment should be able to cut up 460 sq.mm (Wolf conductor)
		Is VDE required or not?	Required
Lot 5: Hand Tools	Item 5(27): Mini Bolt Cutter	What is the cutting capacity?	The cutting capacity shall be up to 48 HRC as given in the specification
		Is VDE required or not?	Not Required
Lot 5: Hand Tools	Item 5(28): Ratchet Cable Cutter	What is the cutting capacity?	The equipment should be able to cut up to 600 sq.mm cable as specified in the technical specification.
		Is VDE required or not?	Required




འབྲུག་གློག་མེ་ལས་འཛིན།

**Bhutan Power Corporation Limited**

(An ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018 Certified Company)

**Registered Office, Thimphu  
Procurement Services Department  
Thimphu: Bhutan**



Lot 2: Electrical Equipment	Item 2(13): Fork Lift	What is the lift height?	The Max lift height shall be 3.5 meter (Refer 4.3 in the specification)
		Is it four-wheeled or 3 - wheeled?	Refer 3.4 of the specification.
Lot 4: Pulley & Ladder	Item 4(6): Ratchet Hoist Pulley	Please provide Chain Length. Standard length is 1.5 meters.	1.5 meters shall be accepted.
Lot 4: Pulley & Ladder	Item 4(7): Single sheave pulley, Open Type	For 10 Ton capacity Pulley the Die cannot be 108mm, 108mm dia pulley shall not take load of 10 Ton, Also the weight stated by you is 4.7 KN. The weight is in Kg, for 10 Ton Single sheave Pulley snatch type weight shall be @ 25 Kg. Please recheck & clarify.	The maximum breaking load of 10MT refers to the maximum safe working force which a pulley can lift the equipment or accessory can exert to lift, suspend, or lower, a given mass without fear of breaking. Please quote as per the technical specification.
Lot 4: Pulley & Ladder	Item 4(11): Aluminum Ladder, extendable 24 ft.	On item description it is stated Aluminum ladder extendable while in technical specification it states Fiberglass Ladder. Please clarify.	Kindly ignore the material description. Please quote as per the technical specification.

This addendum shall form a part of the bidding document and shall be binding.

However, due to the above inclusion and additional information, no time extension shall be granted and the submission date and time shall remain unaltered.

Thanking you,

Yours sincerely,

(Thinley Dorji)

Officiating General Manager